



Sprinkler System Components | Branch Line Alarm Testers | **Sprinkler System Alarm Testers**

Model Q2968

Product Description

Product Specification

Model No	Nominal Pipe Size		K-Factor	Rated Working Pressure		Remarks
	in	(mm)		psi	(kPa)	
Model Q2968	1	(25)	5.6	300	(2065)	a, b, c
Model Q2968	1 1/4	(32)	5.6	300	(2065)	a, c
Model Q2968	1 1/2	(40)	5.6	300	(2065)	a, c
Model Q2968	2	(50)	5.6	300	(2065)	a, b, c

Remarks:

- a. Available with female NPT connections.
- b. Available with grooved connections.
- c. Available with female threaded BSP connections.

Details

Category	Sprinkler System Alarm Testers
Class of Work	1625 - Branch Line Testers
Approval Standard	FM 1625 - Sprinkler System Alarm Test Devices
Certification Type	FM Approved
Listing Country	China

Company

Ningbo Huacheng Valve Co. Ltd.
 No 103 East Chezhan Rd,
 Huangtan Town, Ninghai, Ningbo
 City, Zhejiang 315600 China
 China
<http://huachengvalve.com>